



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK300	5.6	Upright	QR	3 mm*	1/2	Brass, Chrome, Polyester, NICOTEF Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK350	8.0	Upright	QR	3 mm*	1/2, 3/4	Brass, Chrome, Polyester, NICOTEF Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

**Job F3 or Norbulb N3 bulb*

Prepared for: The Viking Corporation, 210 N. Industrial Park Drive, Hastings, MI 49058

Manufacturing Location: 210 North Industrial Park Drive, Hastings, MI 49058

FM Approvals Class: 2016, 2001, 2043

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3045312

Approval Granted: January 14, 2013

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constrictions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in black ink, appearing to read "Richard B. Dunne".

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

