



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

| Model | K | Type | Resp. | Element | NPT (in.) | Finishes | Temperature Ratings °F (°C) |
|---------|-----|------------------|-------|---------|-----------|-------------------------------|---|
| *VK3021 | 5.6 | Pendent | QR | 3mm | 1/2 | Brass, Chrome, Polyester, ENT | 135, 155, 175, 200, 286 (57, 68, 79, 93, 141) |
| *VK3021 | 5.6 | Recessed Pendent | QR | 3mm | 1/2 | Brass, Chrome, Polyester, ENT | 135, 155, 175, 200 (57, 68, 79, 93) |

*Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for:

The Viking Corporation, 5150 Beltway Drive SE
Caledonia, MI 49316, USA

Manufacturing Location:

The Viking Corporation, 5150 Beltway Drive SE
Caledonia, MI 49316, USA

FM Approvals Class: 2015, 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141

Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA