

## **Certificate of Compliance**

This certificate is issued for the following equipment:

## **Automatic Sprinklers for Fire Protection**

Мос	del	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
*VK	3521	8.0	Pendent	QR	3mm	3/4	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
*VK	3521	8.0	Recessed Pendent	QR	3mm	3/4	Brass, Chrome, Polvester, ENT	135, 155, 175, 200 (57, 68, 79, 93)

\*Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for:

The Viking Corporation, 5150 Beltway Drive SE Caledonia, MI 49316, USA

Manufacturing Location:

The Viking Corporation, 5150 Beltway Drive SE Caledonia, MI 49316, USA

FM Approvals Class: 2001, 2015 FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141

Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

-210. 4 rid B. F

David B. Fuller VP, Manager – Fire Protection FM Approvals 1151 Boston-Providence Turnpike Norwood, MA 02062 USA



Member of the FM Global Group